

SIX FLAGS NEW ENGLAND	
SUBJECT: FIRE PROCEDURE	EMERGENCY RESPONSE PROCEDURES
SECTION: 8	PAGE: 1 of 6
EFFECTIVE: JANUARY 2015	SUPERSEDES: ALL PREVIOUS

FIRE PROCEDURE

SIGNAL 33

PURPOSE

This procedure has been established to ensure a safe and timely response in the event of a fire. Also, to ensure that proper notifications are made and that the incident is handled in the proper way.

All fires should be reported to Operations Base by calling extension "3200" or by radio.

To avoid confusion, all reported fires will be checked out by the Safety Department or Security before dispatching any fire equipment. At no time should the word "fire" be used on the radio.

When possible, an attempt shall be made by the employee at the scene to extinguish the fire with a portable fire extinguisher. This should only be done on small fires and only when there is a clear line of retreat available.

When reporting a fire by radio, use the proper radio code (Signal 33), followed by the location of the fire. Below are the definitions of codes used to report a fire:

- SIGNAL 33 A:** Minor fire with little involvement which is of a controlled nature (i.e. trash can or a short circuit in an electrical panel). This type of incident requires only the attention of the department involved, Safety/Security Manager, Security responding unit and additional help depending on the nature of the incident.
- SIGNAL 33 B:** A fire that has potential to be life threatening (i.e. fire involving a building or inside a ride area). This will require the primary response from the department involved, Safety/Security Manager, and Security. Also at the discretion of the Director of Operation, Safety/Security Manager, outside fire service may be called.
- SIGNAL 33 C:** This is a fire that is fully involved and presents a life threatening or disastrous situation to the operation of the park. Primary response will be the department involved, Safety/Security Manager, Security, and outside fire units. Secondary response and notification will be:
- Duty Manager
 - Park President

SIX FLAGS NEW ENGLAND	
SUBJECT: FIRE PROCEDURE	EMERGENCY RESPONSE PROCEDURES
SECTION: 8	PAGE: 2 of 6
EFFECTIVE: JANUARY 2015	SUPERSEDES: ALL PREVIOUS

- Director of Marketing
- Communications/PR
- Department Manager
- Director of Maintenance

If the fire is called Signal 33 C, Operations Base will complete the following steps:

1. Alert and dispatch: Safety, Security and Maintenance
2. Call Agawam Fire Department

A mobile Security unit will be dispatched by Operations Base to meet all incoming fire equipment at turn around and escort to the fire scene. All emergency vehicles should be asked to turn off sirens and emergency lights to avoid alarming guests.

BUILDING EVACUATION -- FIRE

I. Categories of Events and Responses

A. Faint odor of smoke noticed (SIGNAL 33 A)

1. Safety notified -- respond with fire unit
2. Security notified -- responds to back area and stands by
3. Safety Department or designate quickly inspects facility
4. No fire found, Safety re-inspects facility and gives all clear
5. Fire found by Safety Department.
6. Security set up for evacuation
7. Operations Base announces closing of facility
8. All exits opened, guests directed out by Staff and Security
9. Security sets up block points around facility as necessary
10. All facility employees accounted for by Safety Department and effected department Managers, and Security

B. Contained fire found (SIGNAL 33 B)

1. Extinguish with a portable fire extinguisher and notify Safety. If unable to

SIX FLAGS NEW ENGLAND	
SUBJECT: FIRE PROCEDURE	EMERGENCY RESPONSE PROCEDURES
SECTION: 8	PAGE: 3 of 6
EFFECTIVE: JANUARY 2015	SUPERSEDES: ALL PREVIOUS

extinguish or if fire spreads:

2. Safety notified of actual fire, responds to back area, and stands by
3. Security notified of actual fire, responds to back area, and stands by
4. Operation Base calls for outside assistance
5. Security set up for evacuation
6. Operations Base or designate announces closing of facility
7. All exits opened, guests directed out by Staff and Security
8. Security sets up block points around facility as necessary
9. All facility associates accounted for by Safety Department and effected department Managers or designate and Security.

C. Uncontrolled fire found (SIGNAL 33 C)

1. Director of Operations and Safety/Security Manager notified of uncontrollable fire
2. Operations Base under the direction of Safety/Security Manager calls for outside assistance
3. Security notified, responds urgent to back area
4. Safety/Security Manager and maintenance -- Security begins control efforts
5. Security set up for evacuation
6. Duty or designate announces the closing of the facility
7. All unaffected exits opened, guests directed out by Security
8. Security sets up block points around facility as necessary
9. All facility associates accounted for by Department Manager and notify Operations Base.

II. Outside Assistance

SIX FLAGS NEW ENGLAND	
SUBJECT: FIRE PROCEDURE	EMERGENCY RESPONSE PROCEDURES
SECTION: 8	PAGE: 4 of 6
EFFECTIVE: JANUARY 2015	SUPERSEDES: ALL PREVIOUS

- A. Will be escorted by Perimeter Security via best route to fire scene
- B. Will be asked to respond only if there is any possibility that they may be needed.

III. Notification of Management

- A. Safety/Security Manager will notify or designate someone to notify the General Manager, the Director of Operations, and the necessary Departmental Management.

IV. Notification of Possible Fire

- A. If dispatch receives call, they should notify Safety and Security
 - 1. Operations Base will notify the necessary Maintenance personnel
- B. If Safety is directly notified, then Safety will notify Operations Base and necessary Maintenance personnel
- C. If Security is directly notified, they should notify Safety directly or through Base

V. Support Personnel

- A. Marketing
- B. Affected Department Management
- C. Medical Services
- D. Duty Manager
- E. Maintenance

VI. Operations Base Announcement

- A. Ladies and gentlemen, due to unforeseen difficulties, we must close this facility immediately and ask that you follow the exiting directions of our Team Members and Security Officers as promptly as possible.

NOTE: Repeat as necessary, adding "do not push, shove, run, etc." as needed.

SIX FLAGS NEW ENGLAND	
SUBJECT: FIRE PROCEDURE	EMERGENCY RESPONSE PROCEDURES
SECTION: 8	PAGE: 5 of 6
EFFECTIVE: JANUARY 2015	SUPERSEDES: ALL PREVIOUS

HYDRANT LOCATIONS

North Hydrants:

1. Next to Great Chase
2. Behind Shipwreck Shooters in the North
3. Cyclone Access Road by queue house
4. **Infield of Taz's Prop Delivery***
5. **Infield of Flashback by Balloon Race***

Main Street/Center Hydrants

1. Main Gate Bathroom towards staff lot
2. Carousel by the queue line
3. Main Street in center landscaped box in front of lost parents
4. Loony Tunes Emporium on the Gazebo Side
5. Scream Bathrooms
6. Grove Road Behind Thunderbolt
7. Outside of Kidzopolis archway
8. **(2) Inside Whistle Stop Train Town (Access to this will be limited)**

DC Area

1. **Bottom of DC ramp in fence***
2. Bizarro Queue House Entrance
3. **In landscape fence near Catwoman's Whip***

Crack Axle Canyon

1. Next to Crack Axle bathrooms near walkway
2. In front of Stampede Bumper Cars
3. South Side of Maintenance
4. Houdini Pump House (Pump Needs to be activated for water)

South

1. Across from Adult Tea Cups/Splashwater Falls
2. Crime Wave
3. Rockville Gym Pump House (Pump needs to be activated for water)
4. The Works

Hurricane Harbor

1. Hurricane Bay pump house on Access Road Filter 1
2. Red Schooner bathroom
3. Coral Reef Bathroom
4. Tube rental #2, across from Coral Reef Cantina
5. Behind Dippin' Dots Near Entrance

Picnic Grove

1. On grove road behind bar
2. On Grove road behind the bathroom facility

West Lot Approximately 6 are located throughout lot

*** Hydrants with an asterisk are in ride kill zones/infields with limited access**

SIX FLAGS NEW ENGLAND	
SUBJECT: FIRE PROCEDURE	EMERGENCY RESPONSE PROCEDURES
SECTION: 8	PAGE: 6 of 6
EFFECTIVE: JANUARY 2015	SUPERSEDES: ALL PREVIOUS

BUILDINGS WITH SPRINKLER PROTECTION

Maintenance
Rockville Theatre
Hall of Justice
Houdini's Mad House

Food stands with ansul hood systems

River Boat Café
Sweet Shop
Employee Café
Fast Eddies
Rockville Drive In
Kidzopolis Snacks
Primero pizza (by arcade)
The Work's
Johnny Rockets
Captain Leo's
Red Schooner
Coral Reef Cantina
Panda Express
Primero pizza Kidzopolis
Looney Tunes Commissary
Brown Derby
Grove Kitchen
Macho Nacho Mexican Grill

Portable Fire Extinguisher locations